



|        |             |          |                       |
|--------|-------------|----------|-----------------------|
| Number | KIP-15204/G | Replaces | ---                   |
| Issued | 23-12-2016  | Scope    | Directive 2009/142/EC |
| Report | 2001272/1   | Page     | 1 of 2                |
| PIN    | 0476CR1272  |          |                       |

## EC TYPE EXAMINATION CERTIFICATE

**Kiwa Cermet Italia hereby declares that the products**

Storage Condensing water heaters

Trade mark: **COSMOGAS**

Models: AGUAPLUS 60, AGUAPLUS 70, AGUAPLUS 100,  
AGUAPLUS 115, AGUAPLUS 140

Manufactured by **COSMOGAS S.r.l.**  
Meldola (FC), Italy

meets the essential requirements as described in the  
**Directive on appliances burning gaseous fuels 2009/142/EC**

Mentioned products have been approved for

Appliance type: B<sub>23</sub>, C<sub>43</sub>, C<sub>53</sub>, C<sub>63</sub>, C<sub>83</sub>  
Countries: AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB,  
GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT,  
RO, SE, SI, SK, TR

Related to the following gas groups: *as specified in the Annex 1*

The assessment test have been performed using the following standards as  
guidelines:

EN 89:2015

Certificate

**Kiwa Cermet Italia S.p.A.**  
Società con socio unico, soggetta all'attività di  
direzione e coordinamento di Kiwa Italia  
Holding Srl

Via Cadriano, 23  
40057 Granarolo dell'Emilia (BO)


**Unità locale**  
Via Treviso 32/34  
31020 San Vendemiano (TV)

Tel +39. 0438 411755  
Fax +39.0438 22428  
E-mail: [info@kiwacermet.it](mailto:info@kiwacermet.it)  
[www.kiwa.it](http://www.kiwa.it)  
[www.kiwacermet.it](http://www.kiwacermet.it)

**GASTEC**

*The validity of this certificate can be verified by means of a register available on the website [www.kiwa.it](http://www.kiwa.it)  
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements  
of the Directive, as well as on updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa  
Cermet Italia*

Chief Operating Officer  
Giampiero Belcredi



Organismo Notificato n. 0476



Number KIP-15204/G Replaces ---  
Issued 23-12-2016 Scope Directive 2009/142/EC  
Report 2001272/1 Page 2 of 2  
PIN 0476CR1272

## EC TYPE EXAMINATION CERTIFICATE

### ANNEX 1

#### Models:

AGUAPLUS 60, AGUAPLUS 100, AGUAPLUS 115

#### Gas groups:

| Group | mbar  |
|-------|-------|
| E     | 20    |
| H     | 20;25 |
| L     | 25    |

| Group     | mbar  |
|-----------|-------|
| LL        | 20    |
| Esi ,E(S) | 20/25 |
| Er, E(R)  | 20/25 |

| Group | mbar       |
|-------|------------|
| B/P   | 30; 37; 50 |
| P     | 30; 37; 50 |

#### Models:

AGUAPLUS 70, AGUAPLUS 140

#### Gas groups:

| Group | mbar  |
|-------|-------|
| E     | 20    |
| H     | 20;25 |
| L     | 25    |

| Group     | mbar  |
|-----------|-------|
| LL        | 20    |
| Esi ,E(S) | 20/25 |
| Er, E(R)  | 20/25 |

| Group | mbar       |
|-------|------------|
| B/P   | 30; 37; 50 |
| P     | 30; 37; 50 |
| M     | 20         |

*The above gas groups can be combined according to the standard EN437:2009 and national situation of countries.*

Kiwa Cermet Italia S.p.A.

Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23  
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34  
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: [info@kiwacermet.it](mailto:info@kiwacermet.it)

[www.kiwa.it](http://www.kiwa.it)

[www.kiwacermet.it](http://www.kiwacermet.it)